

Model 8016

The 16" Manhole is fabricated for lighter weight and greater strength. The advanced design has low silhouette and clean lines. Fill gasket will not pull out; is easily replaced. To compensate for wear, tension on fill cover is easily adjusted by adding shim washers. Hinge pins welded in place to prevent removal. Adequate means provided for use of seal wire. One outside clamping ring provides means for attaching cover to collar. Cover may be oriented throughout 360°. Secondary Latch is standard on all assemblies.

Cover Plate Fill Gasket Retainer Shim Washer	Clamping Ring Fill Cover Strongback Latch	Clamping Bolt and Washer	Clamping Bolt Nut	Vent	Wt.	Assembly No.
Steel	Steel	Steel Zinc Plt.	Brass	Alum.	20.5	FVA8016SXB
Steel Zinc Plt.	Steel Zinc Plt.	Steel Zinc Plt.	Brass	Alum.	20.5	FVA8016BXB
¦ Stnls 304	Steel Zinc Plt.	Steel Zinc Plt.	Brass	Alum.	20.7	FVA8016GXB
Stnls 304	Stnls 304	Stnls 304	Stnls 304	Alum.	20.7	FVA8016CXB
Stnls 316	Stnls 304*	Stnls 304	Stnls 304	Alum.	20.7	FVA8016DXB
Fill Cooket Peteiner and Shime Aluminum		* Fill Cover Meterial Steiplace 216				

Fill Gasket Retainer and Shims-Aluminum * Fill Cover Material-Stainless 316


Note: Manhole assemblies, as listed above, have a 6238AL vent (prefix "FVA") and Buna-N gaskets (suffix "B"). For variation or additional vents see catalog Section 95 for proper prefix or assembly number. For variation in gasketing change suffix as follows.

Suffix "V" indicates Viton gaskets. Suffix "W" indicates White Hypalon gaskets. Suffix "T" indicates Teflon fill and collar gasket w/ White Hypalon backer

Manhole collars are available in aluminum, steel and stainless steel. Please see parts page for correct numbers. When welding collars to tank, care should be exercised to insure collar remains flat and round.



Tank Truck Service & Sales, Inc. Warren, Michigan 800-482-2678 www.tanktruckservice.com



No.	Description	Material	Part No.
1		Steel	3021MS
	Fill Cover	Steel Zinc Plt.	3021ZC
		Stnls 304	3021SL
		Stnls 316	3021SS
2		Bethane	3024BU
	Fill Gasket	Viton	3024VT
		Wh. Hypalon	3024WH
		Non-Asbestos	3024NA
		Teflon	3024TF
3		Steel	3213MS
	Retainer	Aluminum	3213AL
		Stnls 304	3213SL
		Stnls 316	3213SS
		Steel	3023MS
4	Shim Washer	Aluminum	3023AL
		Stnls 316	3023SS
5	Bolt Clamp	Steel Zinc Plt.	3029ZC
5	Bolt-Clamp	Stnls 304	3029SL
6	Nut-Clamp	Brass	3030BR
	³ / ₈ –16 Thd.	Stnls 304	9Q5809
7	Weeber Clamp	Steel Zinc Plt.	3031ZC
	Washer-Clamp	Stnls 304	3031SL

No.	Description		Material	Part No.
	Clamping Ring		Steel	3028MS
8			Steel Zinc Plt.	3028ZC
			Stnls 304	3028SL
9	E		Buna-N	3559BN
	Manhole Gasket	V	Viton	3559VT
	Channel Type	W	Wh. Hypalon	3559WH
		Т	Teflon Env.	3025TF
			w/ Wh. Hypalon	3023TF
10	Manhole Collar Channel Type		Steel	3057MS
			¹ / ₄ Aluminum	3057AE
			Stnls 304	3057SL
			Stnls 316	3057SS
11	Vent Assembly		Alum./Stnls	6238AL
12	Gasket		Buna-N	3716BN

Gasket Maximum Temperature

Bethane	_250°F
Viton	_400°F
White Hypalon	_250°F
Teflon	_400°F
Teflon Envelope w/ White Hypalon Insert	_250°F
Non-Asbestos	_350°F

MAINTENANCE: Manhole assemblies should be inspected with sufficient frequency and due regard to the products carried to insure a liquid tight closure. Any worn, damaged or missing parts must be replaced. Gaskets should be replaced if their effectiveness is impaired in any way. Replacement gaskets must be compatible with products carried. Adjustment due to gasket wear may be necessary to insure proper sealing of the 10" fill. A shim washer, item No. 4, is provided for this purpose. To increase the sealing force of the 10" fill, remove shim from location shown above and re-position it above fill cover No. 1.

WARNING Use only genuine Betts Industries Inc. replacement parts. Use of substitute parts can impair the proper functioning of this product.



 $2\frac{9}{16}$